

Condensing Unit CU1 - CU 4 3.3kW - 13.0kW



Technical Manual





Customer Services

Warranty, Commissioning & Maintenance

As standard, Airedale guarantees all non consumable parts only for a period of 12 months, variations tailored to suit product and application are also available; please contact Airedale for full terms and details.

To further protect your investment in Airedale products, Airedale can provide full commissioning services, comprehensive maintenance packages and service cover 24 hours a day, 365 days a year (UK mainland).

For a free quotation contact Airedale or your local Sales Engineer.

All Airedale products are designed in accordance with EU Directives regarding prevention of build up of water, associated with the risk of contaminants such as legionella.

For effective prevention of such risk it is necessary that the equipment is maintained in accordance with Airedale recommendations.

CAUTION

Warranty cover is not a substitute for maintenance. Warranty cover is conditional to maintenance being carried out in accordance with the recommendations provided during the warranty period. Failure to have the maintenance procedures carried out will invalidate the warranty and any liabilities by Airedale International Air Conditioning Ltd.

Spares

A spares list for 1, 3 and 5 years will be supplied with every unit and is also available from our Spares department on request.

Training

As well as our comprehensive range of products, Airedale offers a modular range of Refrigeration and Air Conditioning Training courses, for further information please contact Airedale.

Customer Services

For further assistance, please e-mail: connect@airedale.com or telephone:

UK Sales Enquiries + 44 (0) 113 239 1000 connect@airedale.com International Enquiries + 44 (0) 113 239 1000 connect@airedale.com Spares Hot Line + 44 (0) 113 238 7878 spares@airedale.com Airedale Service + 44 (0) 113 239 1000 service@airedale.com Technical Support + 44 (0) 113 239 1000 tech.support@airedale.com Training Enquiries + 44 (0) 113 239 1000 training@airedale.com

For information, visit us at our web site: www.airedale.com

Airedale Ltd. endeavours to ensure that the information in this document is correct and fairly stated, but none of the statements are to be relied upon as a statement or representation of fact. Airedale Ltd. does not accept liability for any error or omission, or for any reliance placed on the information contained in this document. The development of Airedale products and services is continuous and the information in this document may not be up to date. It is important to check the current position with Airedale Ltd. at the address stated. This document is not part of a contract or licence unless expressly agreed. No part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or information storage and retrieval systems, for any purpose other than the purchaser's personal use, without the express written permission of Airedale Ltd. ©2019 Airedale International Air Conditioning Limited. All rights reserved. Printed in the UK.

Health and Safety

IMPORTANT

The information contained in this manual is critical to the correct operation and maintenance of the unit and should be read by all persons responsible for the installation, commissioning and maintenance of the Airedale unit.

The equipment has been designed and manufactured to meet international safety standards but, like any mechanical/ electrical equipment, care must be taken if you are to obtain the best results.

CAUTION A

When working with any air conditioning units ensure that the electrical isolator is switched off prior to servicing or repair work and that there is no power to any part of the equipment.

Also ensure that there are no other power feeds to the unit such as fire alarm circuits, BMS circuits

Electrical installation commissioning and maintenance work on this equipment should be undertaken by competent and trained personnel in accordance with local relevant standards and codes of practice.

The refrigerant used in this range of products is classified under the COSHH regulations as an irritant, with set Workplace Exposure Levels (WEL) for consideration if this plant is installed in confined or poorly ventilated areas. A full hazard data sheet in accordance with COSHH regulations is available should this be required.

Protective Personal Equipment

Airedale recommends that personal protective equipment is used whilst installing, maintaining and commissioning equipment.

Refrigerant Warning

This Airedale unit uses R407C refrigerant which requires careful attention to proper storage and handling procedures. Use only manifold gauge sets designed for use with R407C refrigerant. Use only refrigerant recovery units and cylinders designed for high pressure refrigerants. R407C must only be charged in the liquid state to ensure correct blend makeup. The refrigerant must be stored in a clean, dry area away from sunlight and must never be stored above 50°C.

Global Warming Potential

The R407C refrigerant has a GWP of 1774 (based on EN378-1:2016, 100 year life)

Pressure Equipment Directive (2014/68/EU)

Minimum and Maximum Operation Temperature (TS) and Pressure (PS)

Refrigeration

Allowable Temperature Range (TS), = Min -20°C* to Max 120°C**

Maximum Allowable Pressure (PS), = High Side 27.6 Barg

*Based on the refrigerant temperature in the unit off state in the lowest permitted ambient temperature.

Manual Handling

Some operations when servicing or maintaining the unit may require additional assistance with regard to manual handling. This requirement is down to the discretion of the engineer. Remember do not perform a lift that exceeds your

Environmental Policy

It is our policy to:

- Take a proactive approach to resolve environmental issues and ensure compliance with regulatory requirements
- Train personnel in sound environmental practices
- Pursue opportunities to conserve resources, prevent pollution and eliminate waste
- Manufacture products in a responsible manner with minimum impact on the environment
- · Reduce our use of chemicals and minimise their release to the environment
- Measure, control and verify environmental performance through internal and external audits
- Continually improve our environmental performance

CE Directive

Airedale certify that the equipment detailed in this manual conforms with the following EC Directives:

Electromagnetic Compatibility Directive (EMC) 2014/30/EU

Machinery Directive (MD) 89/392/EEC version 2006/42/EC

Pressure Equipment Directive (PED) 2014/68/EU

To comply with these directives appropriate national & harmonised standards have been applied. These are listed on the Declaration of Conformity, supplied with each product.

^{**}Based on the maximum allowable super-heated refrigerant temperature.

Contents	
Introduction	5
Nomenclature	5
Standard Features	5
Optional Extras	6
Capacity Data	7
Cooling Only Unit	7
Heat Pump Unit	8
Technical Data	9
Mechanical Data	9
Electrical Data	10
Sound Data	10
Operating Limits	11
Dimensions	12
Field Connections	13
pLAN Terminations	14
After Sales	15
Warranty	15

General Description


Introduction

This range of 8 air cooled condensing units and heat pumps covers the range of 3.3 to 13 kW in cooling mode. All condensing units are factory fitted with head pressure control and mains isolator as standard. The range is custom designed for a small footprint, low noise level, slimline and aesthetically pleasing appearance and lend themselves to wall mounting applications. These units can be used with many Airedale products from the mini split Answer Cassette and Concept 2000 units, Comfort modular comfort products and close control products. They can also be utilised as heat rejection equipment for applications featuring other cooling units.

Construction

Unit cabinets are manufactured from galvanised sheet steel coated with epoxy baked powder paint to provide a durable finish. The standard unit colour is Light Grey (RAL 7035).

Access to the compressors is via removable panels at the end and side of the units.



Standard Features

Condenser

The large surface area coil is manufactured from refrigeration quality cooper tubes with mechanically bonded aluminium fins and is ideally positioned to optimise airflow and heat transfer.

Fan Motor & Assembly

The axial flow fan assembly has low noise sickly type blades and an inlet ring.

The external rotor motor allows the use of a low power output, single phase and speed controllable motor to power the fan. The motor has inbuilt thermal overload protection and the assembly is supplied complete with a finger guard for protection.

Compressor

CU/CUH 1 - 1.5

Fully hermetic reciprocating compressor fitted as standard with internal thermal motor protection. Compressor(s) are mounted to the base via the use of vibration isolators.

Hermetic scroll compressors fitted as standard with internal thermal motor protection and internal pressure relief valve. Compressor(s) are mounted to the base via the use of vibration isolators.

Refrigeration

Cooling only units feature as standard:

- Liquid line shut off valve
- Suction line shut off valve
- · High and low pressure switches
- Filter dryer (loose)
- Operating charge

Heat pump units feature as standard:

Each unit features as standard:

- Liquid line shut off line
- · Suction line shut off valve
- · High and low pressure switches
- Filter dryer (loose)
- Reversing valve
- Defrost function
- Oil sump heater
- Suction line accumulator
- Check valve (TEV inbuilt)
- Externally equalised bi-directional thermostatic expansion valve

Controls

A custom designed microprocessor system has been developed and is fitted to the units as standard so that an Airedale indoor unit can be matched to the condensing unit, and communication is available via a simple 2-wire link.

The microprocessor is programmed with compressor anticycle protection to prevent short cycling and subsequent additional wear on the compressor, limiting the compressor starts to 6 per hour. As an additional feature, communication between indoor and outdoor microprocessor units is carried by means of a low voltage 2 core screened cable. A set of volt free contacts, to relay a unit trip, is provided as standard. Alternatively, the condensing unit can be supplied with electro-mechanical controls – refer to Optional Extras for details.

Flectrical

The unit control panel is fitted with the necessary contactors, sub-circuit protection and terminals to allow efficient and continuous unit operation. All wiring is colour coded and numbered for identification and all units are wired to current local and European standards.

Head Pressure Control

Head pressure is maintained by a factory fitted head pressure controller which varies the speed of the fan(s) to provide optimum control under varying ambient conditions.

Mains Electric Isolator

The mains electric isolator ensures complete unit isolation of the electrical panel during adjustment and maintenance. The factory-fitted isolating device is a door interlocking type, preventing the panel from being accessed when the unit is running.

Optional Extras

Epoxy Coated Condenser Coils

In atmospheres where high corrosion is anticipated, epoxy coated aluminium finned coils can be fitted to provide extra protection.

Wall Mounting Brackets

A bracket and fixing kit for wall mounting can be supplied.

Defrost Drain Tray

A stainless steel drain tray can be provided to collect condensate when units are used in heat pump mode. This is recommended for wall mounted installations.

Hot Gas Bypass

To achieve capacity control during low load conditions or to maintain suction pressure when used with fresh air systems, the hot gas bypass system will modulate the capacity down to 40% of full load. A stub is provided for site connection of the hot gas line to the local expansion device. The hot gas option is supplied as a loose field fit kit.

Electro-Mechanical Controls

The condensing unit can be supplied with electro-mechanical controls to operate via a cooling/heating signal from the indoor unit. This is suitable where the condensing unit is matched to a non-Airedale indoor unit.

Phase Rotation Protection

A phase sequence relay is available for units containing 3 phase scroll compressors, to prevent possible damage by running the compressor in the wrong direction.

Capacity Data - Cooling Only Unit

			Ambient									
	Mean	25	C.	30°	C.	35	°C	40°	C.	45	C.	
Cooling Duty	Evaporating Temperature	Output kW	Input kW									
	-5	2.62	0.90	2.45	1.04	2.30	1.19	2.13	1.33	1.96	1.47	
CU1	0	3.11	0.95	2.92	1.08	2.73	1.23	2.55	1.37	2.35	1.51	
001	5	3.70	0.98	3.50	1.12	3.30	1.26	3.10	1.41	2.90	1.55	
	10	4.32	1.02	4.11	1.15	3.90	1.28	3.67	1.44	3.44	1.59	
	-5	3.57	1.27	3.35	1.47	3.14	1.68	2.91	1.87	2.68	2.08	
CU1.5	0	4.25	1.31	4.02	1.52	3.79	1.71	3.55	1.92	3.31	2.13	
001.5	5	5.05	1.38	4.79	1.58	¦ 4.51	1.78	4.24	1.99	¦ 3.97	2.19	
	10	5.90	1.44	5.62	1.63	5.33	1.81	5.02	2.04	4.70	2.25	
	-5	4.01	1.09	3.76	1.26	3.52	1.44	3.27	1.61	3.01	1.79	
CUS2	0	4.77	1.13	4.51	1.31	4.25	1.47	3.98	1.65	3.71	1.83	
0032	5	5.67	1.19	¦ 5.37	1.36	¦ 5.06	1.53	4.76	1.71	4.45	1.88	
	10	6.62	1.24	6.30	1.40	5.98	1.56	5.63	1.75	5.27	1.93	
	-5	5.97	1.74	5.61	2.01	5.24	2.26	4.83	2.55	4.41	2.83	
CUS2.5S	0	7.12	1.82	6.73	2.08	6.34	2.34	5.90	2.63	5.46	2.91	
0032.33	5	8.40	1.93	7.98	2.18	7.55	2.42	7.06	2.73	6.56	3.01	
	10	9.80	2.03	9.32	2.27	8.84	2.51	8.26	2.80	7.68	3.08	
	-5	5.90	1.72	5.69	2.00	5.47	2.27	5.27	2.54	5.53	2.82	
CUS2.5T	0	7.18	1.83	6.81	2.08	6.43	2.34	6.07	2.59	5.66	2.90	
0032.31	5	8.40	1.91	¦ 7.99	2.17	¦ 7.57	2.42	7.13	2.71	6.68	2.99	
	10	9.70	2.02	9.25	2.27	8.79	2.51	8.31	2.79	7.82	3.07	
	-5	6.99	2.13	6.62	2.44	6.26	2.75	5.91	3.07	5.50	3.44	
CUS3	0	8.28	2.27	7.86	2.54	7.44	2.81	6.99	3.14	6.54	3.53	
0000	5	9.69	2.38	9.20	2.69	8.72	2.96	8.22	3.30	7.67	3.63	
	10	11.20	2.51	10.67	2.79	10.12	3.09	9.55	3.42	8.99	3.74	
	-5	8.66	2.48	8.19	2.79	7.71	3.10	7.23	3.42	6.75	3.73	
CUS3.5	0	10.38	2.60	9.82	2.91	9.25	3.21	8.72	3.54	8.18	3.86	
0000.0	5	12.35	2.77	11.53	3.05	10.76	3.33	10.24	3.66	9.72	3.98	
	10	14.18	2.93	13.29	3.20	12.39	3.46	11.89	3.79	11.39	4.12	
	-5	10.56	2.50	9.85	2.98	9.18	3.46	8.54	3.95	8.54	3.95	
CUS4	0	12.44	2.63	11.74	3.11	11.05	3.59	10.32	4.07	9.78	4.61	
0004	5	14.54	2.86	¦ 13.80	3.33	¦ 13.05	3.79	12.37	4.27	11.75	4.80	
	10	16.95	3.11	16.17	3.56	15.38	4.00	14.51	4.42	13.62	5.00	

¹ Output kW refers to the compressor duty.

² Input kW refers to the compressor input power only.
3 Cooling data for a cooling only unit.

Capacity Data - Heat Pump Unit

			Ambient									
	Mean	25	°C	30°	°C	35	°C	40°	C.	45°	,C	
Cooling Duty	Evaporating Temperature	Output kW	Input kW									
	-5	2.62	0.90	2.45	1.04	2.30	1.19	2.13	1.33	1.96	1.47	
CUH1	0	3.11	0.95	2.92	1.08	2.73	1.23	2.55	1.37	2.35	1.51	
	5	3.70	0.98	¦ 3.50	1.12	¦ 3.30	1.26	3.10	1.41	¦ 2.90	1.55	
	10	4.32	1.02	4.11	1.15	3.90	1.28	3.67	1.44	3.44	1.59	
	-5	3.57	1.27	3.35	1.47	3.14	1.68	2.91	1.87	2.68	2.08	
CUH1.5	0	4.25	1.31	4.02	1.52	3.79	1.71	3.55	1.92	3.31	2.13	
00111.0	5	5.05	1.38	4.79	1.58	¦ 4.51	1.78	4.24	1.99	¦ 3.97	2.19	
	10	5.90	1.44	5.62	1.63	5.33	1.81	5.02	2.04	4.70	2.25	
	-5	3.85	1.05	3.61	1.21	3.38	1.38	3.14	1.55	2.89	1.72	
CUHS2	0	4.58	1.08	4.33	1.26	4.08	1.41	3.82	1.58	3.56	1.76	
001102	5	5.44	1.14	¦ 5.16	1.31	4.86	1.47	4.57	1.64	4.27	1.80	
	10	6.36	1.19	6.05	1.34	5.74	1.50	5.40	1.68	5.06	1.85	
	-5	5.73	1.67	5.39	1.93	5.03	2.17	4.64	2.45	4.23	2.72	
CUHS2.5S	0	6.84	1.75	6.46	2.00	6.09	2.25	5.66	2.52	5.24	2.79	
001102.00	5	8.06	1.85	7.66	2.09	7.25	2.32	6.78	2.61	¦ 6.30	2.89	
	10	9.41	1.95	8.95	2.10	8.49	2.41	7.93	2.69	7.37	2.96	
	-5	5.66	1.65	5.46	1.92	5.25	2.18	5.06	2.44	5.31	2.71	
CUHS2.5T	0	6.89	1.76	6.54	2.00	6.17	2.25	5.83	2.49	5.43	2.78	
001102101	5	8.06	1.83	¦ 7.67	2.08	7.27	2.32	6.84	2.60	¦ 6.41	2.87	
	10	9.31	1.94	8.88	2.18	8.44	2.41	7.98	2.68	7.51	2.95	
	-5	6.71	2.04	6.36	2.34	6.01	2.64	5.67	2.95	5.28	3.30	
CUHS3	0	7.95	2.18	7.55	2.44	7.14	2.70	6.71	3.01	6.28	3.39	
001100	5	9.30	2.28	8.83	2.58	8.37	2.84	7.89	3.17	7.36	3.48	
	10	10.75	2.41	10.24	2.00	9.72	2.97	9.17	3.28	0.00	3.59	
	-5	8.31	2.38	7.86	2.68	7.40	2.98	6.94	3.28	6.48	3.58	
CUHS3.5	0	9.96	2.50	9.42	2.79	8.88	3.08	8.37	3.39	7.85	3.71	
5555.0	5	11.86	2.66	11.09	2.93	10.33	3.20	9.83	3.51	9.33	3.82	
	10	13.61	2.81	12.75	3.07	11.89	3.32	11.41	3.64	10.93	3.96	
	-5	10.14	2.40	9.46	2.86	8.81	3.32	8.20	3.79	8.20	3.79	
CUHS4	0	11.94	2.52	11.27	2.99	10.61	3.45	9.91	3.91	9.39	4.43	
33.104	5	13.96	2.75	13.25	3.20	12.53	3.64	11.88	4.10	11.28	4.61	
	10	16.27	2.99	15.52	3.42	14.75	3.84	13.93	4.27	13.08	4.80	

¹ Output kW refers to the compressor duty.

³ Cooling data for a cooling only unit.

			Mean Condensing Temperature								
			30°C	35°C	40°C	45°C	50°C	55°C			
		Outdoor Air	Output	Output	Output	Output	Output	Output			
Heating Duty	°C	On %RH	kW	kW	kW	kW	kW	kW			
	5	85	3.81	3.76	3.70	3.72	3.70	3.51			
CUH1	7	85	4.02	3.95	3.90	¦ 3.91	¦ 3.75	3.63			
	10	80	4.29	4.22	4.16	<u>.</u> 4.16	<u>.</u> 4.15	4.11			
	5	85	4.70	4.63	4.62	4.59	4.57	4.55			
CUH1.5	7	85	4.98	4.90	4.87	¦ 4.84	¦ 4.80	4.78			
	10	80	5.32	5.23	5.19	5.14	5.31	5.41			
	5	85	5.44	5.37	5.29	5.32	5.29	5.01			
CUHS2	7	85	5.74	5.65	5.57	¦ 5.59	¦ 5.36	5.19			
!	10	80	6.13	6.03	5.94	5.94	5.93	5.88			
	5	85	8.14	8.02	7.99	7.95	7.91	7.87			
CUHS2.5S	7	85	8.63	8.49	8.43	8.38	¦ 8.31	8.27			
	10	80	9.19	9.04	8.99	8.93	8.87	8.72			
	5	85	8.14	8.02	7.99	7.95	7.91	7.87			
CUHS2.5T	7	85	8.63	8.49	8.43	8.38	¦ 8.31	8.27			
	10	80	9.19	9.04	8.99	<u>!</u> 8.93	<u>!</u> 8.87	8.77			
	5	85	9.30	9.25	9.20	9.17	9.12	9.09			
CUHS3	7	85	9.83	9.79	9.77	9.77	9.76	9.73			
	10	80	10.59	1046	10.32	10.26	10.20	10.08			
	5	85	11.92	11.71	11.62	11.51	11.40	11.32			
CUHS3.5	7	85	12.61	12.36	12.27	¦ 12.15	12.00	11.89			
	10	80	13.51	13.23	13.12	<u>!</u> 12.95	12.78	12.59			
	5	85	13.57	13.51	13.48	13.43	13.38	13.36			
CUHS4	7	85	14.34	14.25	14.21	14.14	¦ 14.06	14.01			
	10	80	15.42	15.19	15.08	15.05	14.89	14.79			

¹ Output kW refers to the compressor duty.

² Input kW refers to the compressor input power only.

² Indoor ambient at 20°C.

Technical Data Mechanical Data

CU/CUH	1	1.5	S2	S2.5S	S2.5T	S3	S3.5	S4
Nominal Capacity - Cooling (1) kW	3.3	4.5	5.1	7.6	7.6	8.7	10.8	13.1
Nominal Input (1) kW	1.3	1.8	1.5	2.4	2.4	3	3.3	3.8
Capacity Steps %	0-100	0-100	0-100	0-100	0-100	0-100	0-100	0-100
Dimensions								
Height mn	n 828	828	828	828	828	1143	1140	1140
Width mn	n 395	395	395	395	395	395	395	395
Length mn	n 937	937	935	935	935	940	935	935
Condenser								
Туре				Air C	ooled			
Quantity	1	1	1	1	1	1	1	1
Face Area m²	0.76	0.76	0.76	0.76	0.76	0.89	0.89	0.89
Nominal Airflow m³/	s 0.80	8.0	0.8	8.0	0.8	8.0	1.45	1.8
Coil Volume (2)	2.03	2.03	2.03	4.33	4.33	5.12	5.12	5.12
Discharge				Horiz	ontal			
Fans								
Туре	İ			Ax	tial			
Quantity	1	1	1	1	1	1	2	2
Diameter mn	1 400	400	400	400	400	400	400	400
Maximum Speed rpn	1430	1430	1430	1430	1430	1430	1430	1430
Compressor								
Туре	Reci	procating			Sc	roll		
Quantity	1	1	1	1	1	1	1	1
Oil Charge Volume L	0.6	1.2	1	1.1	1.1	1.1	1.9	1.6
Refrigeration								
Number of Circuits	1	1	1	1	1	1	1	1
Refrigerant Type				R40)7C			
Holding Charge kg				Inert	Gas			
Refrigeration Control			Thermos	static Expans	ion Valve (C	UH Only)		
Weights CU Units								
Machine Weight (nom) kg	50.2	58.0	57.2	73.5	73.5	85.0	98.6	101.0
Operating Weight (nom) kg	51.0	59.0	60.2	75.7	75.7	88.1	101.6	104.1
Weights CUH Units								
Machine Weight (nom) kg	52.2	60.0	58.6	75.4	75.4	80.4	103	103.4
Operating Weight (nom) kg	53	61.0	61.8	78.4	78.4	83.6	106	109.4
Connections								
Liquid Line (3) in	1/4	1/4	1/4	3/8	3/8	3/8	3/8	1/2
Suction Line (3) in	1	E/0	5 (0		0/4		2/4	2/4
(-)	5/8	5/8	5/8	3/4	3/4	3/4	3/4	3/4

⁽¹⁾ Nominal Capacity based on 5°C mean evaporating temperature and a 35°C ambient.

⁽²⁾ Figures for guidance.

⁽³⁾ Flare connections on service valves.

Technical Data Electrical Data

CU/CUH	1	1.5	S2	S2.5S	S2.5T	S3.0	S3.5	S4.0
Unit Data								
Nominal Run Amps (1) A	6	9.7	10.3	14.3	6.4	7.1	8.8	9.5
Maximum Start Amps A	35.0	59.0	49.6	78.6	39.1	46.6	59.2	67.0
Control Circuit VA	230	230	230	230	230	230	230	230
Mains Supply V		23	0/1/50			400)/3/50	
Rec. Mains Fuse A	16	16	16	20	16	16	16	20
Max Incoming Mains mm	6	6	6	6	6	6	6	6
Compressor								
Motor Rating kW	1.1	1.7	1.7	2.5	2.5	2.9	3.7	4.0
Nominal Run Amps (1) A	5.5	9.4	9.6	13.6	5.7	6.4	7.5	8.2
Locked Rotor Amps A	37.5	61.0	47.0	76.0	36.5	44.0	54.0	61.8
Crankcase Heater Rating (2) W	24	24	40	40	40	40	65	65
Type of Start				Direct	on Line			
Condenser Fan								
Motor Rating kW	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
Full Load Amps A	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.78
Locked Rotor Amps A	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25


- (1) Nominal data based on 5°C evaporating temperature and a 35°C ambient.
- (2) Heat Pump units only.

Sound Data


	Sound				Fr	equency (F	lz)		
	Measurement		dBA	125	250	500	1000	2000	4000
CU/CUH	Power	dBA	64	67	67	62	59	53	46
1 - 1.5	Pressure	@ 1 m	53	40	47	49	48	43	36
	Pressure	@ 10 m	33	20	27	29	28	23	16
CUS/CUHS	Power	dBA	73	79	73	70	66	60	55
2 - 3	Pressure	@ 1 m	62	71	63	59	58	52	47
	Pressure	@ 10 m	42	51	43	39	38	32	27
CUS/CUHS	Power	dBA	73	79	75	72	66	64	57
3.5 - 4	Pressure	@ 1 m	65	71	67	64	58	56	49
	Pressure	@ 10 m	45	51	47	44	38	36	29


⁽¹⁾ Above noise levels are with the condenser fan running at full speed. Under normal operating conditions (ambients up to 35°C) noise levels will be reduced by 3 - 4 dB.

Operating Data Operating Limits Cooling Only



Heat Pump





Field Connections

Microprocessor Controlled (AD05)

	L1	← ←	Mains incoming 230/1/50
	S1A 0 S1B 0	→	Communication connection to indoor unit (microprocessor only)
CONDENSING UNIT	COOL O COM O HEAT O	↓ ←	External control of cool/heat mode (volt free) ⁽¹⁾
	A3 O A3 O	$\begin{array}{c} \rightarrow \\ \rightarrow \end{array}$	Optional auxiliary alarm Volt free input (normally closed = healthy)
	DS1 0 DS2 0	$\begin{array}{c} \rightarrow \\ \rightarrow \end{array}$	Defrost status indication Volt free contact (normally closed = defrosting)
	CCA 0 CA1 0 CA2 0	$\begin{array}{c} \rightarrow \\ \rightarrow \\ \rightarrow \\ \rightarrow \end{array}$	Common Normally closed contact Normally open contact Common alarm changeover volt free contacts

System Field Connections for AD05 Controlled Units

-,	 					
	L1	0		0	L1	
	N	0		0	N	
INDOOR UNIT	E	0		0	E	AD05 CONTROLLED
INDOOR UNIT						OUTDOOR UNIT
	S1A	0	$\leftarrow \rightarrow$	0	S1A	
	S1B	0	$\leftarrow \rightarrow$	0	S1B	

(1) The microprocessor (AD05) controlled condensing unit may be matched to non Airedale indoor air handling units. A contact can be closed across with the Cool and Common or Heat and Common terminals. Ensure that the cooling and heating cannot be initialised simultaneously.

Electro-Mechanically Controlled Units


Cooling Only Units

	L1 L2 L3 N	0 0 0 0	\rightarrow	Mains incoming 230/1/50 or 400/3/50
CU. 1-4	34	0	\rightarrow	Compressor signal from indoor unit
	 576 577	0	$\overset{\rightarrow}{\rightarrow}$	Cooling signal from 24vac controlled indoor unit
	 589 502	0	\rightarrow	589/502 volt free contact for unit trip indicator
	N1	0	\rightarrow	Control neutral (if required)

Heat Dump Unite

neat Fullip Utilis				
	L1 L2 L3 N E	0 0 0 0	\rightarrow	Mains incoming 230/1/50 or 400/3/50
	34	0	\rightarrow	Compressor signal from indoor unit
CUH. 1-4	35	0	\rightarrow	Cooling signal from indoor unit
	36	0	\rightarrow	Defrost signal from indoor unit
	589 502	0	\rightarrow	589/502 volt free contact for unit trip indication
	N1	0	\rightarrow	Control neutral (if required)

pLAN Terminations



IMPORTANT: The plugged termination ensures that the connections are made simultaneously. Failure to attach the cables in this way may cause damage to the controller.

After Sales

Warranty

All Airedale products or parts (non consumable) supplied for installation within the UK mainland and commissioned by an Airedale engineer, carry a full Parts & Labour warranty for a period of 12 months from the date of commissioning or 18 months from the date of despatch, whichever is the sooner.

Parts or Equipment supplied by Airedale for installation within the UK or for Export that are properly commissioned in accordance with Airedale standards and specification, not commissioned by an Airedale engineer; carry a 12 month warranty on non consumable Parts only from the date of commissioning or 18 months from the date of despatch, whichever is the sooner.

Parts or equipment installed or commissioned not to acceptable Airedale standards or specification invalidate all warranty.

Warranty is only valid in the event that

In the period between delivery and commissioning the equipment:

- is properly protected & serviced as per the Airedale installation & maintenance manual provided
- where applicable the glycol content is maintained to the correct level.

In the event of a problem being reported and once warranty is confirmed* as valid under the given installation and operating conditions, the Company will provide the appropriate warranty coverage (as detailed above) attributable to the rectification of any affected Airedale equipment supplied (excluding costs for any specialist access or lifting equipment that must be ordered by the customer).

*Once warranty is confirmed, maintenance must be continued to validate the warranty period.

Any spare part supplied by Airedale under warranty shall be warranted for the unexpired period of the warranty or 3 months from delivery, whichever period is the longer. To be read in conjunction with the Airedale Conditions of Sale - Warranty and Warranty Procedure, available upon request.

Procedure

When a component part fails, a replacement part should be obtained through our Spares department. If the part is considered to be under warranty, the following details are required to process this requirement. Full description of part required, including Airedale's part number, if known. The original equipment serial number. An appropriate purchase order number.

A spares order will be raised under our warranty system and the replacement part will be despatched, usually within 24 hours should they be in stock. When replaced, the faulty part must be returned to Airedale with a suitably completed and securely attached "Faulty Component Return" (FCR) tag. FCR tags are available from Airedale and supplied with each Warranty order.

On receipt of the faulty part, suitably tagged, Airedale will pass to its Warranty department, where it will be fully inspected and tested in order to identify the reason for failure, identifying at the same time whether warranty is justified or not.

On completion of the investigation of the returned part, a full "Report on Goods Returned" will be issued. On occasion the release of this complete report may be delayed as component manufacturers become involved in the investigation. When warranty is allowed, a credit against the Warranty invoice will be raised. Should warranty be refused the Warranty invoice becomes payable on normal terms.

Exclusions

Warranty may be refused for the following reasons.

- Misapplication of product or component
- Incorrect site installation
- Incomplete commissioning documentation
- Inadequate site installation
- Inadequate site maintenance
- Damage caused by mishandling
- Replaced part being returned damaged without explanation
- Unnecessary delays incurred in return of defective component

Returns analysis

All faulty components returned under warranty are analysed on a monthly basis as a means of verifying component and product reliability as well as supplier performance. It is important that all component failures are reported correctly.



Head Office
Airedale International Air Conditioning Ltd
Leeds Road
Rawdon
Leeds LS19 6JY
Tel: +44 (0) 113 2391000
Fax:+44 (0) 113 2507219
E-mail connect@airedale.com

Web www.airedale.com

